

Village of Arlington Heights

In Response to Public Works Comments dated May 10, 2019

1. The 8" PVC Pipe has been changed to a 10" PVC per the engineering plans and will be addressed prior to permit.
2. It is understood that the village will not maintain the culverts and that the village does not require a maintenance agreement. The maintenance of the culvert will be the responsibility of the homeowner.
3. The property currently sits with an existing home on the property and the water flow from east to west is void of a culvert currently. We do not anticipate any drainage issues as there have not been any in the past decades. Currently there is no culvert or culverts that run along the North side of Thomas Ave or existing ditch between the edge of the pavement and the sidewalk.
4. Understood.

Marcie Glueckert-Heidkamp

RECEIVED
MAY 21 2019
PLANNING & COMMUNITY
DEVELOPMENT DEPARTMENT

RECEIVED
MAY 12 2019
PLANNING & COMMUNITY
DEVELOPMENT DEPARTMENT

Village of Arlington Heights

In Response to Plan Commissions PC #18-025

Dated 4-26-19

11. Understood

12. Understood

13. Understood

14. The Estoppel Agreement has been signed, notarized, and returned to the Village.

15. The \$4,716 fee in lieu of detention is considered permit fees and will be part of the building permit process.

16. Range 13 has been changed to Range 11

17. Understood

Marcie Glueckert-Heidkamp

RECEIVED
MAY 21 2019
**PLANNING & COMMUNITY
DEVELOPMENT DEPARTMENT**