

**AN ORDINANCE AMENDING CHAPTER 21  
OF THE ARLINGTON HEIGHTS MUNICIPAL CODE**

SECTION ONE: That Article IV, Cross Connection Control, located in Chapter 21, Water, of the Arlington Heights Municipal Code, is hereby amended as follows (the language being added is highlighted):

1. That Section 21-401, Cross Connections Prohibited, is hereby amended by adding the following subsection:

- e. The control of all cross-connections to the water supply is the responsibility of the owner or official custodian of the supply and that such connections, when permitted, are the responsibility of the public water supply officials.

2. That subsection b. of Section 21-402, Surveys, Inspections and Investigations, is hereby amended as follows:

- b. Surveys, inspections and investigations shall be made by the Director of Public Works or authorized agent on an interval determined to be reasonable, proper, and sufficient to insure that cross-connections do not exist. A cross-connection control survey of the distribution system shall be conducted by the official custodian or an authorized delegate.

3. That Section 21-403 Cross Connection Prevention, is hereby amended by adding the following subsection:

- d. All backflow devices shall be installed in accordance with the Illinois Plumbing Code, 77 Ill. Adm. Code 890, where the owner or official custodian of the water supply observes or becomes aware of an actual or potential risk.

4. That subsections b. and e. of Section 21-405, Testing and Certification, are hereby amended as follows:

- b. Testing and certification of all cross-connection control devices shall be done at least annually. The cross-connection control program shall include a record system which will maintain data on inspections, re-inspections, repairs, alterations and tests. All testing shall only be performed by inspectors approved by the Illinois EPA as cross-connection control device inspectors (CCCDI). The inspection of mechanical devices shall include physical testing in accordance with the manufacturer's instructions.
- e. Maintenance, as recommended by the manufacturer of a required device,

will be performed on all cross-connection control devices protecting the municipal water works system. The Manufacturer's Maintenance Manuals are required to be available on-site at the location of each device. Costs for maintaining, repairing or replacing cross-connection control devices protecting the municipal water works system shall be borne by the Village, unless the maintenance, repair or replacement is necessitated by freezing, negligence or other controllable act.

SECTION TWO: This Ordinance repeals all ordinances or parts of ordinances in conflict with the provisions hereof, and shall be in full force and effect after its passage, approval and publication in pamphlet form, in the manner provided by law.

AYES:

NAYS:

PASSED AND APPROVED this 6th day of March, 2017.

\_\_\_\_\_  
Village President

ATTEST:

\_\_\_\_\_  
Village Clerk